



**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE FIRE SERVICES DEPARTMENT  
RENEWAL OF NO OBJECTION CERTIFICATE**



Ack. No.:	413400002019	Issue Date :	05/12/2019	
NOC:	00016448/REJ/Rangareddy/2019			
NOC TYPE:	RENEWAL*			
Valid Upto:	31/12/2024			

**Applicant Details:** Venkata Varaprasada Varma-8897277755/Prerana Waldorf School, plot no 47/9, jhanardhan hills, Gachibowli, Hyderabad

**Building for which NOC issued:** PRERANA WALDORF SCHOOL- plot no – 47/9, jhanardhan hills /

**Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening:** No

<b>Plot Area (Sq. Mtrs):</b> 4058.00	<b>Total Built-up Area (Sq.Mtrs):</b> 9670.00	<b>Height ( Metres):</b> 20.55
--------------------------------------	---	--------------------------------

<b>Open Spaces (Metres):</b>	<b>North Provided:</b> 7.00	<b>South Provided:</b> 7.00	<b>East Provided:(F)</b> 7.00	<b>West Provided:</b> 7.00
------------------------------	-----------------------------	-----------------------------	-------------------------------	----------------------------

<b>No. of Floors:</b> Cellar1,Stilt1,Ground0,Floor5,Terrace0	<b>Occupancy Type:</b>	EDUCATIONAL B-1 Schools up to senior secondary level
--	------------------------	--

**Please find below the deficits:**

<b>Open Spaces (Metres):</b>	<b>North :</b> 1.00	<b>South:</b> 1.00	<b>East:</b> 0.00	<b>West:</b> 1.70
------------------------------	---------------------	--------------------	-------------------	-------------------

<b>Staircases:</b>	<b>No. of Staircases Deficit:</b>	0
	<b>Minimum width of any one staircase (Metres):</b>	
	<b>Aggregate Width Deficit (Metres):</b>	3.34

**Deficits in Minimum Requirements for Fire Fighting Installations as per Table 7, Part-IV of NBC, 2016:**

<b>Fire Extinguisher:</b>	0	<b>First Aid Hose Reel:</b>	0	<b>Wet Riser:</b>	0
---------------------------	---	-----------------------------	---	-------------------	---

<b>Down Comer:</b>	0	<b>Yard Hydrant:</b>	0	<b>Automatic Sprinkler System:</b>	0
--------------------	---	----------------------	---	------------------------------------	---

<b>Manually Operated Electronic Fire Alarm Systems:</b>	0	<b>Terrace Tank (Litres):</b>	20000		
---	---	-------------------------------	-------	--	--

<b>Automatic Detection and Alarm System:</b>	0	<b>Underground Static Water Storage Tank (Litres):</b>	0		
--	---	--	---	--	--

<b>Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm2 at Terrace Level</b>	<b>Type</b>	<b>Quantity</b>	<b>(Capacity in Litres/min)</b>
	Electrical	0	0
	Diesel	0	0
	Electrical	0	0

<b>Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm2</b>	<b>(Capacity in Litres/min)</b>
	900

**"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"**